



SECTION 10155
TOILET COMPARTMENTS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Stainless steel partitions. Ceiling Hung.

1.2 RELATED SECTIONS

- A. Section 05500 - Metal Fabrications: Concealed steel support members.
- B. Section 06110 - Wood Framing: Concealed wood framing and blocking for compartment support.
- C. Section 10800 - Toilet and Bath Accessories.

1.3 REFERENCES

- A. ASTM International:
 - 1. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
 - 2. ASTM D 1735 - Standard Practice for Testing Water Resistance of Coatings Using Water Fog Apparatus
 - 3. ASTM D 2247 - Standard Practice for Testing Water Resistance of Coatings in 100 percent Relative Humidity
- B. United States Green Building Council (USGBC): LEED Green Building Rating System.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Literature indicating typical panel, pilaster, door, hardware and fastening.
 - 2. Preparation instructions and recommendations.
 - 3. Storage and handling requirements and recommendations.
 - 4. Installation methods.
- C. Shop Drawings:
 - 1. Dimensioned plans indicating layout of toilet compartments.
 - 2. Dimensioned elevations indicating heights of doors, pilasters, separation partitions, and other components; indicate locations and sizes of openings in compartment separation partitions for toilet and bath accessories to be installed in partitions; indicate floor and ceiling clearances.
 - 3. Details indicating anchoring components (bolt layouts) and methods for project conditions; indicate components required for installation, but not supplied by toilet compartment manufacturer.
- D. Selection Samples: For each finish product specified, one complete set of color selection

guides representing manufacturer's full range of available colors, textures and patterns.

- E. Verification Samples: For each finish product specified, two samples representing actual product, color, texture and pattern.
- F. LEED Green Building Rating System: Submit manufacturer's documentation of recycled content, in accordance with LEED credit calculations.
- G. Manufacturer's Certificates: Certify products meet or exceed specified requirements.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store and handle materials and products in strict compliance with manufacturer's instructions and recommendations and industry standards.
- B. Store products indoors in manufacturers' or fabricator's original containers and packaging, with labels clearly identifying product name and manufacturer. Protect from damage.
- C. Lay cartons flat, with adequate support to ensure flatness and to prevent damage to pre-finished surfaces.
- D. Do not store where ambient temperature exceeds 120 degrees F (49 degrees C).

1.6 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.
- B. Do not deliver materials or begin installation until building is enclosed, with complete protection from outside weather, and building temperature maintained at a minimum of 60 degrees F (15.6 degrees C).

1.7 WARRANTY

- A. Manufacturers Standard Warranty: Provide warranty for Stainless Steel Material: Against corrosion or discoloration for 5 years, assuming proper maintenance according to manufacturer's recommendations.

1.8 COORDINATION

- A. Coordinate Work with placement of support framing and anchors in walls and ceilings.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Basis of Design: ASI Accurate Partitions, Integrated Privacy Compartments, which is located at: 160 Tower Drive, Burr Ridge, IL 60527; Tel: 708-442-6800; Fax: 708-442-7439; Web: <http://asi-accuratepartitions.com>
 - 1. No other manufacturer accepted without ASTM performance compliance.
- B. Requests for substitutions considered in accordance with provisions of Section 01600.

2.2 COMPARTMENTS AND SCREENS

- A. Toilet Compartments: Ceiling Hung.
 - 1. Compartment Depth and Width: As scheduled and indicated on Drawings.
 - 2. Door Width: 24 inches (610 mm) minimum non-ADA doors. ADA accessible compartments 36 inches (915 mm) minimum.
 - 3. Height Above Floor: 12 inches (305 mm).

4. Door/Panel Height: 58 inches (1,473 mm).
- B. Privacy and Urinal Screens: Wall hung.
1. Screen Panel Size: 24 inches (610 mm) wide by 48 inches (1219 mm) high.
 2. Height Above Floor: 12 inches (305 mm).

2.3 STAINLESS STEEL TOILET COMPARTMENTS

- A. Doors, Panels, Screens, and Pilasters: Tension leveled 304 stainless steel face sheet with #4 finish, bonded under pressure to honeycomb core with non-toxic adhesive.
1. Doors, Screens, and Panels: 1 inch (25 mm) thick, 22-gauge (0.793 mm) steel.
 2. Pilasters: Ceiling Hung, 1-1/4 inches (32 mm) thick, 18-gauge (1.21 mm) steel.
 3. Edge Molding: Continuous roll-formed, interlocking 22-gauge (0.793 mm) steel crown molding, joined by corner clips at the corners.
 4. Finish: Type 304 stainless steel, #4 finish.
 5. Edge Molding for Door: Integrated, sight line blocking, molding affixed to door during fabrication. Formed by continuous roll form process. Type 304 SS, 22-gauge (.793 mm) steel molding.
- B. No-Sight System: Integral to door construction required.
1. Add-on no sight strips not allowed.
 2. Brushed finish.
 3. Use of 304 stainless steel required.
- C. Door Hardware: Attached with theft resistant barrel nuts and shoulder screws.
1. Finish: Chromium plated Zamac.
 2. Hinges: Top hinge recessed in door and interlocked with nylon pin in the plane of the door. Bottom hinge recessed in door with mating nylon box and pintle cams providing the bearing surface. Adjustable to allow door to rest at any position within a 270-degree range. Top and bottom hinges are through-bolted.
 3. Latch: ASI Privacy Indicator slide latch installed on factory prepared door. Emergency access provided by slotted occupancy indicator on outside of door.
 4. Handicapped Access: Provided via slide latch functionality of ASI Privacy Indicator latch.
 5. Coat Hook and Bumper: Manufacturer's standard surface mounted.
 6. Door Pull: Standard on ADA compartments. Two per ADA door.
 7. Fastening Hardware: Theft resistant pin-head.
- D. Mounting Brackets: Chromium plated stirrup brackets with theft resistant fasteners.
- E. Pilaster Shoes: Type 304 stainless steel, #4 finish. 5 inches (127 mm) high minimum secured to ceiling with internal clips.
- F. Pilaster Anchors: Ceiling Hung.
1. 0.116 inches (2.9 mm) slotted channel welded to top of pilaster, with two 3/8-inch (9.5 mm) diameter cadmium-plated studs anchoring bracket to structure overhead.
 2. Concealed by pilaster shoe after installation.

PART 3 EXECUTION

3.1 EXAMINATION AND PREPARATION

- A. Inspect and prepare substrates using the methods recommended by the manufacturer for achieving best result for the substrates under project conditions. Clean surfaces thoroughly prior to installation.
- B. Do not proceed with installation until substrates have been prepared using the methods recommended by the manufacturer and deviations from manufacturer's recommended

tolerances are corrected. Commencement of installation constitutes acceptance of conditions.

- C. If preparation is the responsibility of another installer, notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions.
 - 1. Verify dimensions of areas to receive compartments.
 - 2. Verify locations of built-in framing, anchorage, bracing, and plumbing fixtures.

3.2 INSTALLATION

- A. Install in accordance with approved shop drawings and manufacturer's instructions.
- B. Fasten components to adjacent materials and to other components using purpose-designed fastening devices.
- C. Adjust pilaster anchors for substrate variations; conceal anchors with pilaster shoes.
- D. Equip each compartment door with hinges and door latch.
- E. Equip each compartment door with one coat hook and bumper.
- F. Installation Tolerances:
 - 1. Maximum variations from plumb or level: 1/8 inch (3 mm).
 - 2. Clearance between wall surface and panels or pilasters: 1-1/2-inch (38 mm) maximum.

3.3 ADJUSTING

- A. Adjust and align hardware to uniform clearance at vertical edge of doors.
- B. Adjust adjacent components for consistency of line or plane.

3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. Remove factory protective coverings and clean finish surfaces in accordance with manufacturer's instructions before substantial completion.